

DRAGON PID PARAMETERS

15-Apr-14

SECURE MENU	
InP	VoLt
OSUP	OFF
Unit	nonE
dPt	000.0
InPt	OFF
SEnC	OFF
SCAL	000.0
SCAH	500.0
SPL	0.2
SPH	100.0
SP1o	OutA
S1Ot	Volt
S1St	rE
S1OL	0
S1OH	60
S1LP	0
AL	OFF
Addr	don't care
RS485 etc.	don't care

SECONDARY MENU		
Auto	On	
ALLo	don't care	
ALLHI	don't care	
tunE	PID	
	Pb1	2.6
	rES	1.7
	rtE	OFF
ArUP	On	
ArtE	OFF	
PEA	don't care	
VAL	don't care	
S1Ot	Volt	
PctO	OFF	
Prog	OFF	
StAt	off	
1rt	0.00	
1St	0.00	
Pend	don't care	
InPC	0	
FILt	2	
LPbr	OFF	
LOCE	don't care	
RS485 etc.	don't care	